



**EL DORADO COUNTY  
FIRE PROTECTION DISTRICT**

P.O. Box 807/4040 Carson Road / Camino, CA 95709  
(530) 644-9630 Fax (530) 644-9636

## **Alternative Measures for Providing a Reasonable Degree of Life Safety in Agricultural Buildings in El Dorado County**

### **Criteria:**

- The building shall be for agricultural use only.
- Items sold shall be products produced on the Farm/Ranch.
- The building shall not exceed 2000 square feet
- No other buildings within 50 feet of the building in question.
- The building shall be on Agriculturally Zoned property.
- A special use permit shall be obtained for the operation being conducted; any variation from this permit will constitute either a resubmit for a new permit, or the revocation of the issued permit.
- A high degree of expense, out weighting the cost of the project, must be presented prior to allowing alternative measures.
- Seasonal Operations only.

### **Alternative measures:**

- The installation of a N.F.P.A. 13R Sprinkler System.
- An Early Detection System (Fire Alarm) that warns the occupants of the building and is monitored 24 hours a day, 7 days a week.
- Vegetation management and fuel modifications around all concerned buildings(s).
- Limited hours of operation
- Provide adequate access and egress for emergency personnel and occupants.
- On site water storage tank(s) for fire protection.
- Fire Dept. access to water used for irrigation.
- Fire Resistive Roof Coverings.